



GOVERNMENT OF HARYANA

Department of Industries & Commerce, Haryana,

From

The Chief Inspector of Boilers, Haryana
30, Bays Building, 1st Floor Room No.60,
Sector - 17, Chandigarh.
Phone: 0172-2704052

To

Ms Arshya Engineers & Fabrications (p) Ltd.
Plyala- Dundsa Road, Village- Dundsa,
Distt. Palwal, Haryana

Memo No. 187

Dated. 02-07-2020

Subject:- **Grant of permission for the manufacturing of IBR Pipe Fittings ,Flanges, Fabricated Fittings, Pipe (Plate Formed),Piping Spool and Fabricated Equipment's under IBR, 1950.**

In continuation of this office Memo No. 207 dated 04.07.2013 and your request Letter No. AEPL/IBR/20/04 Dated 16.06.2020 on the subject noted above.

You are hereby allowed to Manufacturing the **of IBR Pipe Fittings ,Flanges, Fabricated Fittings, Pipe (Plate Formed),Piping Spool and Fabricated Equipment's** Under Indian Boiler Regulations-1950 on the followings terms and conditions:-

1. That you will get the Design and Drawing approved before starting the job.
2. That you will deposit in advance the inspection fee required for drawing approval and for construction purposes.
3. That you will submit the program of the various inspection job to be under taken well in advance i.e. 24th of every month.
4. That you will maintain observation sheet for recording stages of inspection.
5. That you will follow the stage of inspection as required under Indian Boiler Regulations-1950.
 - a. Material identification.
 - b. Test plate stamping after forging.
 - c. Mechanical testing of sample.
 - d. Dimensional check up.
 - e. Non Destructive Testing (If Applicable).
 - f. Final inspection and stamping.
6. That you will employ qualified Boiler welder as required under reg. 604 of Indian Boiler Regulations-1950, where the welding work involved.
7. That you will put up the certificates in Form IIIA / IIIC / IIIG for signature of Inspecting officer / Inspecting Authority within 15 days of final inspection.
8. That you will maintain the record of certification for at last 10 years from the date of its certification.
9. If there is any violation of any clause of Indian Boiler Regulation-1950.This approval will stand Withdraw.


Chief Inspector of Boilers,
Haryana, Chandigarh